

DRIVEWAY AND SIDEWALK SPECIFICATIONS

(CURB CUT SPECIFICATIONS FOR DRIVEWAYS)

RESIDENTIAL DRIVEWAYS

- 1. THE APPROACH APRON MUST BE A MIN. OF 6" THICK**
- 2. THE APRON WINGS AT EACH END OF DRIVEWAY MIN. 5'
FROM SIDEWALK TO FLAT OF LOWER ELEVATION OF DRIVEWAY**
- 3. FROM STREET GUTTER TO LOWER ELEVATION OF
DRIVEWAY THE HEIGHT IS MIN. 1" / MAX 2"**
- 4. MUST USE 3000 LB CONCRETE**
- 5. USE MEDIUM BRUSH FINISH**

COMMERCIAL DRIVEWAYS

- 1. THE APPROACH APRON MUST BE A MIN. 6" THICK**
- 2. APRON WINGS SAME AS ABOVE**
- 3. STREET GUTTER SAME AS ABOVE**
- 4. MUST BE 3000 LB CONCRETE**
- 5. MUST INSTALL #4 (1/2") REBAR ON 12" CENTERS IN A
SQUARE PATTERN**
- 6. USE MEDIUM BROOM FINISH**
- 7. MUST COMPACT TO SUB GRADE WITH APPROVED
AGGREGATE**

CONTRACTORS MUST SHOW PROOF OF LIC. # AND BOND